



Department of Commerce

Safety & Buildings Division

201 West Washington Avenue

P.O. Box 2658

Madison, WI 53701-2658

Evaluation # 200252-R (Replaces 200030-R)

Wisconsin Building Products Evaluation

(Text of evaluation is incomplete, lacks diagrams. For complete copy of evaluation, contact the department)

Material

EnerBlock Insulated Concrete
Masonry Units

Manufacturer

West Materials, Inc.
P.O. Box 195
Amery, WI 54001

SCOPE OF EVALUATION

GENERAL: This report evaluates EnerBlock insulated concrete masonry units, manufactured by West Materials, Inc. The EnerBlock insulated concrete masonry units were evaluated for use as an insulation material with specified "R" values.

This review includes the cited **Comm** code requirements below in accordance with the current **Wisconsin Uniform Dwelling Code (UDC), (for 1- and 2-family dwellings):**

- **Thermal Performance:** The EnerBlock insulated concrete masonry units were evaluated in accordance with the thermal performance calculation requirements of **s. Comm 22.31**. The "R" values may be used in heat gain and heat loss calculations as required by **s. Comm 22.31 (4) and (5)**

This review includes the cited **International Building Code (IBC)** requirements below in accordance with the current **Wisconsin Amended IBC Code:**